



GUAM MEMORIAL HOSPITAL AUTHORITY

ATURIDÅT ESPETÅT MIMURIÅT GUÅHÅN

850 Governor Carlos Camacho Road, Tamuning, Guam 96913
Operator: (671) 647-2330 or 2552 | Fax: (671) 649-5508



AMENDMENT #4

GMHA Invitation for Bid No. 003-2026

Urgent Care Heat Ventilation and Air Conditioning (HVAC) Improvement Project

This Amendment is in response to a Request for Information by JWS Refrigeration & Air Conditioning, LTD:

Question: We're requesting to extend the submission of the proposal until February 27, 2026. We're still waiting for the prices of the equipment from our vendors and other items needed for this proposed project.

Response:

Bid submission reads as 9:30 a.m., Monday, February 9, 2026, at the Materials Management Dept.
Bid submission shall now read as 9:30 a.m., Friday, February 20, 2026, at the Materials Management Dept.

Bid opening reads as 9:45 a.m., Monday, February 9, 2026 at the FM Conference Room.

Bid opening shall now read as 9:45 a.m., Friday, February 20, 2026 at the FM Conference Room.

Question: We are requesting clarification regarding whether all outdoor air-conditioning and ventilation ductwork is constructed from galvanized steel sheets.

Response: All outdoors A/C and vent ductwork should be hospital grade stainless steel such as type 316L.

Question: We kindly request additional details, type, and specifications pertaining to the outdoor duct insulation, specifically regarding the two-inch thick exterior insulation with stainless steel jacket outlined in Drawing No. M4.1.

Response: Must be ASTM C612 Mineral wool board as preferred for hospital grade use.

All others shall remain the same. Please acknowledge receipt of this amendment by signing and sending back to Materials Management by Fax at 671-649-3640 or email to materials.mgmt@gmha.org.

If you have any questions, please feel free to address your letter to Joleen M. Aguon, MD, and fax to the Materials Management Office at 671-649-3640 or email to the materials.mgmt@gmha.org.

Sincerely,

DOLORES PANGELINAN
Hospital Materials Management Administrator

ACKNOWLEDGMENT:

PRINT NAME

SIGNATURE

DATE