



GUAM MEMORIAL HOSPITAL AUTHORITY

ATURIDÁT ESPETÁT MIMURIÁT GUÅHÅN

850 Governor Carlos Camacho Road, Tamuning, Guam 96913
Operator: (671) 647-2330 or 2552 | Fax: (671) 649-5508



January 21, 2022

AMENDMENT #2 FOR

GMHA IFB 009-2022 LABORATORY HVAC SYSTEM UPGRADE PROJECT

TO: All prospective bidders,

This Amendment is being issued to change the following:

1) **Vendor:** Based on model for the exhaust fan reflected on plan there's no explosion proof motor selection for Greenheck.

GMHA: Submit equal or better for review and approval.

2) **Vendor:** Time extension for bid submission.

BID Submission as Reads:

Bid will be accepted on or before 10:00 am, Chamorro Standard Time, February 8, 2022, and Public Opening at 10:30 am Chamorro Standard Time, February 8, 2022.


Change to Read:

Bids will be accepted on or before 10:00 am, Chamorro Standard Time, February 16, 2022, and Public Opening at 10:30 am Chamorro Standard Time, February 16, 2022.

3) **Vendor:** We would like to request for another site visit for above subject project.

GMHA: 2nd Site visit on Monday 1/24/22 @ 0900 hours.

If any other questions/clarifications please send via telefax addressed to Mrs. Lillian Perez-Posadas, MN, RN.



Dolores F. Pangelinan,
Hospital Materials Management Administrator

Acknowledgment of Receipt: Return acknowledgment to fax number 649-3640

Company

Print Name

Signature Date